

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

GAF 1361 Alps Road Wayne, NJ 07470

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF Conventional Built-Up Roof System for Wood Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises and renews NOA No. 07-1219.09 consists of pages 1 through 17. The submitted documentation was reviewed by Juan E. Collao, R.A.



Juan Collas

NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 1 of 17

ROOFING SYSTEM APPROVAL

Category:RoofingSub-Category:BURMaterial:FiberglassDeck Type:WoodMaximum Design Pressure:-75 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT: TABLE 1

<u>Product</u>	<u>Dimensions</u>	Test Specification	Product <u>Description</u>
GAFGLAS® #75 Base Sheet	39.37" (1 meter) Wide	ASTM D 4601	Type II asphalt impregnated and coated glass mat base sheet.
GAFGLAS [®] #80 Ultima [™] Base Sheet	39.37" (1 meter) Wide	ASTM D 4601	Type II asphalt impregnated and coated, fiberglass base sheet.
GAFGLAS [®] FlexPly [™] 6	39.37" (1 meter) Wide	ASTM D 2178	Type VI asphalt impregnated glass felt with asphalt coating.
GAFGLAS® Ply 4	39.37" (1 meter) Wide	ASTM D 2178	Type IV asphalt impregnated glass felt with asphalt coating.
GAFGLAS® Mineral Surfaced Cap Sheet	39.37" (1 meter) Wide	ASTM D 3909	Asphalt coated, glass fiber mat cap sheet surfaced with mineral granules.
GAFGLAS [®] EnergyCap [™] BUR Mineral Surface Cap Sheet	39.37" (1 meter) wide	ASTM D3909	Asphalt coated, glass fiber mat cap sheet surfaced with mineral granules with factory applied EnergyCote TM
GAFGLAS [®] Stratavent [®] Eliminator [™] Perforated Venting Base Sheet	39.37" (1 meter) Wide	ASTM D 4897	Fiberglass base sheet coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating with factory perforations.
GAFGLAS® Stratavent® Eliminator™ Nailable Venting Base Sheet	39.37" (1 meter) Wide	ASTM D 4897	A nailable, fiberglass base sheet impregnated and coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating.
Ruberoid [®] SBS Heat- Weld [™] Smooth	39.37" (1 meter) Wide	ASTM D 6164	Non-Woven Polyester mat coated with polymer-modified asphalt and smooth surfaced.
Ruberoid [®] SBS Heat- Weld [™] 25	39.37" (1 meter) Wide	ASTM D 6164	Non-Woven Polyester mat coated with polymer-modified asphalt and smooth surfaced.
Ruberoid® 20	39.37" (1 meter) Wide	ASTM D 6163	SBS modified asphalt base sheet reinforce with a glass fiber mat.



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 2 of 17

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT: TABLE 1

Product	<u>Dimensions</u>	Test Specification	Product <u>Description</u>
Ruberoid® Mop Smooth	39.37" (1 meter) wide	ASTM D 6164	Non-woven polyester mat coated with polymer-modified asphalt and smooth surfaced.
FireOut [™] Fire Barrier Coating	5, 55 gallons	Proprietary	Low VOC, water based fire barrier coating.
VersaShield® Fire Resistant Roof Deck Protection	350 sq ft. roll	ASTM D 226	Non-Asphaltic Fiberglass-Based Underlayment.
Topcoat® Surface Seal SB	5 gallons	ASTM D 6083	Solvent based sprayable thermoplastic rubber sealant designed to protect and restore aged roof surfaces and to increase a roof's reflectivity.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	Product Description	<u>Manufacturer</u> (With Current NOA)
EnergyGuard [™] Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard [™] RA Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard [™] RN Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard [™] Perlite Roof Insulation	Perlite insulation board.	GAF
EnergyGuard TM Perlite Recover Board	Perlite recover board	GAF
EnergyGuard [™] RA Composite Polyiso Insulation	Polyisocyanurate foam insulation with high density fiberboard or Permalite perlite insulation	GAF
Securock® Gypsum-Fiber Roof Board	Gypsum roof board	USG Corporation
Structodek® High Density Fiber Board	High density fiber board	Blue Ridge FiberBoard, Inc.



NOA No.: 13-0424.09 **Expiration Date: 11/04/14** Approval Date: 10/31/13

Page 3 of 17

APPROVED FASTENERS:

TABLE 3

<u>Fastener</u> <u>Number</u>	<u>Product</u> <u>Name</u>	<u>Product</u> <u>Description</u>	Dimensions	<u>Manufacturer</u> (With Current NOA)
1.	Drill-Tec [™] #12 Fastener	Insulation fastener for steel, wood & concrete decks.	various	GAF
2.	Drill-Tec [™] #14 Fastener	Insulation fastener for steel, wood & concrete decks.	various	GAF
3.	Drill-Tec [™] XHD Fastener	Carbon steel extra heavy duty fastener used in steel decks.	Various	GAF
4.	Drill-Tec [™] ASAP 3S	Drill-Tec [™] #12 Fastener with Drill-Tec [™] 3" Standard Steel Plate	Various	GAF
5.	Drill-Tec [™] 3" Steel Plate	Round galvalume stress plate used with Drill-Tec [™] fasteners.	3" round	GAF
6.	Drill-Tec [™] 3" Standard Steel Plate	Round galvalume plated steel stress plate with reinforced ribs for use with Drill-Tec [™] fasteners.	3" round	GAF
7.	Drill-Tec [™] AccuTrac [®] Flat Plate	AZ-SS aluminized steel plate for use with Drill-Tec [™] #12 Fastener, Drill-Tec [™] #14 Fastener and Drill-Tec [™] #15 Fastener.	3" square	GAF
8.	Drill-Tec [™] AccuTrac [®] Recessed Plate	Galvalume Steel plate for use with Drill-Tec TM fasteners.	3" square	GAF



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 4 of 17

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Description	Date
Factory Mutual Research Corp.	J.I. 2B8A4.AM	4470	07/02/97
•	J.I. 3B9Q1.AM	4470	01/08/98
	J.I. 0D0A8.AM	4470	07/09/99
	J.I. 0D1A8.AM	4470 - TAS 114	07/29/94
	J.I. 0Y9Q5.AM	4470 - TAS 114	04/01/98
	3029832	4470 - TAS 114	05/11/07
PRI Asphalt Technologies, Inc.	GAF-084-02-01	ASTM D 6083	05/09/06
	GAF-314-02-01	ASTM D 2178	08/23/11
	GAF-315-02-01	ASTM D 2178	08/23/11
	GAF-276-02-01Rev	ASTM D 6083	12/16/10
	GAF-276-02-02	ASTM D 226	11/15/10
	GAF-270-02-02	ASTM D 226	11/15/10
IRT of S. Fl.	02-005	TAS 114	01/18/02
	02-014	TAS 114	03/22/02
Trinity ERD	G6850.08.07-1	ASTM D 3909	08/13/07
<i>7</i> 1	G34140.04.11-4	ASTM D 6401	04/25/11
	G30250.02.10-3-R1	ASTM D 3909	11/26/12
	G34140.04.11-5	ASTM D 4897	04/25/11
	G34140.04.11-5-R1	ASTM D 4897	10/18/13
	G34140.04.11-2	ASTM D 6163	04/25/11



NOA No.: 13-0424.09 **Expiration Date: 11/04/14** Approval Date: 10/31/13 Page 5 of 17

APPROVED ASSEMBLIES

Deck Type 1I: Wood, Insulated

Deck Description: $\frac{19}{12}$ or greater plywood or wood plank

System Type A: Anchor sheet mechanically fastened, all layers of insulation adhered with approved asphalt.

All General and System Limitations shall apply.

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard TM Polyiso Insulation, EnergyGuard TM RA Polyiso Polyiso Insulation	Insulation, EnergyGuard™ RA	\ Composite
Minimum 1" thick	N/A	N/A
EnergyGuard™ Perlite Recover Board		
Minimum ½" thick	N/A	N/A
EnergyGuard TM Perlite Roof Insulation Minimum ³ / ₄ " thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down. GAF requires either a ply of GAFGLAS[®] Stratavent[®] EliminatorTM Perforated Venting Base Sheet laid dry or a layer of EnergyGuardTM Perlite Roof Insulation or wood fiber overlay board on all isocyanurate applications.

Fire Barrier: FireOut™ Fire Barrier Coating, VersaShield® Fire-Resistant Roof Deck Protection or

(optional) Securock® Gypsum Fiber Roof Board.

Anchor sheet: GAFGLAS® #80 UltimaTM Base Sheet, GAFGLAS® Stratavent® EliminatorTM Nailable

Venting Base Sheet, Ruberoid® 20, Ruberoid® SBS Heat-Weld™ Smooth or Ruberoid®

Heat-Weld™ 25 base sheet mechanically fastened as described below;

Fastening Options: GAFGLAS® Ply 4, GAFGLAS® Flex PlyTM 6, GAFGLAS® #75 Base Sheet or any of above

anchor sheets attached to deck with approved annular ring shank nails and tin caps at a fastener spacing of 9" o.c. at the lap staggered and in two rows 12" o.c. in the field.

(Maximum Design Pressure -45 psf, See General Limitation #7)

GAFGLAS® Ply 4, GAFGLAS® FlexPlyTM 6, GAFGLAS® #75 Base Sheet or any of above anchor sheets attached to deck with Drill-TecTM #12 Fastener, Drill-TecTM #14 Fastener and Drill-TecTM 3" Steel Plate, Drill-TecTM AccuTrac® Flat Plate or Drill-TecTM AccuTrac® Recessed Plate 12" o.c. in 3 rows. One row is in the 2" side lap. The other rows are equally

spaced approximately 12" o.c. in the field of the sheet.

(Maximum Design Pressure –45 psf, See General Limitation #7)



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 6 of 17 GAFGLAS® FlexPlyTM 6, GAFGLAS® #75 Base Sheet or any of above anchor sheets attached to deck with approved annular ring shank nails and tin caps at a fastener spacing of 9" o.c. at the 4" lap staggered and in two rows 9" o.c. in the field.

(Maximum Design Pressure -52.5 psf, See General Limitation #7)

GAFGLAS[®] #80 Ultima[™] Base Sheet, Ruberoid[®] 20, Ruberoid[®] Mop Smooth, base sheet attached to deck with approved 1½" annular ring shank nails and inverted 3" steel plate at a fastener spacing of 9" o.c. at the 4" lap and in two rows staggered with a fastener spacing of 9" o.c. in the center of the membrane.

(Maximum Design Pressure -60 psf, See General Limitation #7)

GAFGLAS® #75 Base Sheet or any of above anchor sheets attached to deck with Drill-TecTM #12 Fastener, Drill-TecTM #14 Fastener and Drill-TecTM 3" Steel Plate, Drill-TecTM AccuTrac® Flat Plate or Drill-TecTM AccuTrac® Recessed Plate 12" o.c. in 4 rows. One row is in the 2" side lap. The other rows are equally spaced approximately 9" o.c. in the field of the sheet.

(Maximum Design Pressure -60 psf, See General Limitation #7)

Any of above anchor sheets attached to deck approved annular ring shank nails and 3" inverted Drill-TecTM insulation plates at a fastener spacing of 9" o.c. at the 4" lap staggered in two rows 9" in the field.

(Maximum Design Pressure -60 psf, See General Limitation #7)

GAFGLAS® #75 Base Sheet or any of above anchor sheets attached to deck with Drill-TecTM #12 Fastener or Drill-TecTM #14 Fastener and 3" Drill-TecTM 3" Steel Plate, Drill-TecTM AccuTrac® Flat Plate or Drill-TecTM AccuTrac® Recessed Plate 8" o.c. in 4 rows. One row is in the 2" side lap. The other rows are equally spaced approximately 9" o.c. in the field of the sheet.

(Maximum Design Pressure –75 psf, See General Limitation #7)

Base Sheet:

Optional) Install one ply of GAFGLAS[®] #75 Base Sheet, GAFGLAS[®] #80 UltimaTM Base Sheet, GAFGLAS[®] Stratavent[®] EliminatorTM Perforated Venting Base Sheet, Ruberoid[®] Mop Smooth, Ruberoid[®] 20, Ruberoid[®] SBS Heat-WeldTM Smooth or Ruberoid[®] SBS Heat-WeldTM 25 directly over the top layer of insulation. Adhere with any approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq; (see General Limitation #4).

Ply Sheet:

One or more plies GAFGLAS® PLY 4, GAFGLAS® Flex PlyTM 6 sheet or GAFGLAS® #80 Ultima Base Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 7 of 17 Cap Sheet: (Optional) One ply of GAFGLAS® Mineral Surfaced Cap Sheet or GAFGLAS®

EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved

asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: Optional on granular surfaced membranes; required for smooth membranes. Chosen

components must be applied according to manufacturer's application instructions.

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.

2. Topcoat® Surface Seal SB applied at 1to 1.5 gal./sq.

Maximum Design

Pressure: See Fastening above.



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13

Page 8 of 17

Deck Type 1I: Wood, Insulated

Deck Description: 19/32" or greater plywood or wood plank

System Type B: Optional base sheet laid dry; base layer of insulation mechanically fastened, optional top layer

adhered with approved asphalt.

All General and System Limitations shall apply.

One or more layers of any of the following insulations.

Insulation for Base Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ Polyiso Insulation, EnergyGuard™ RA Polyiso Insulation 1.3" thick	1, 2, 3 or 4	1:3 ft²
EnergyGuard™ RN Polyiso Insulation Minimum 1.4" thick	1, 2, 3 or 4	1:3 ft²
EnergyGuard™ RA Composite Polyiso Insulation Minimum 1.5 thick	3	1:3 ft²
EnergyGuard™ Perlite Roof Insulation Minimum ¾" thick	1, 2, 7 or 8	1:2 ft²
Structodek [®] High Density Fiberboard Minimum 1" thick	1, 2, 7 or 8	1:4 ft²

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details). GAF requires either a ply of GAFGLAS® Stratavent® Eliminator™ Perforated Venting Base Sheet laid dry or a layer of EnergyGuard™ Perlite Roof Insulation or wood fiber overlay board on all isocyanurate applications.

Insulation for Top Layer (Table 2)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Any of the insulations listed for Base Layer, above.	N/A	N/A
Structodek® High Density Fiberboard, EnergyGuard™ Perlito	e Recover Board	
Minimum ½" thick	N/A	N/A

Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Fire Barrier: FireOut[™] Fire Barrier Coating, VersaShield[®] Fire Resistant Roof Deck Protection or

(optional) SecurockTM Gypsum Fiber Roof Board.



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 9 of 17 **Base Sheet:** (Optional) Install one ply of GAFGLAS[®] #75 Base Sheet, GAFGLAS[®] #80 Ultima[™] Base

Sheet, GAFGLAS® Ply 4, GAFGLAS® FlexPly™ 6, GAFGLAS® Stratavent® Eliminator™
Perforated Venting Base Sheet laid dry, Ruberoid® Mop Smooth or Ruberoid® 20 directly over the top layer of insulation. Adhere with any approved mopping asphalt applied within the EVT

range and at a rate of 20-40 lbs./sq. (See General Limitation #4).

Ply Sheet: Two or more plies of GAFGLAS® Ply 4, GAFGLAS® FlexPlyTM 6 or GAFGLAS® #80 Ultima

Base Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at

a rate of 20-40 lbs./sq. (See specification number for appropriate number of plies).

Cap Sheet: (Optional) One ply of GAFGLAS[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCapTM

BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See GAF application instructions for approved

method of installation).

Surfacing: Optional on granular surfaced membranes; required for smooth membranes. Chosen components must be applied according to manufacturer's application instructions

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.

2. Topcoat[®] Surface Seal SB applied at 1to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf; (See General Limitation #7)



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 10 of 17 **Deck Type 1I:** Wood, Insulated

Deck Description: $^{19}/_{22}$ " or greater plywood or wood plank

System Type C: One or more layers of insulation simultaneously attached; Base layer optional.

All General and System Limitations shall apply.

One or more layers of any of the following insulations.

Insulation for Base Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard TM RN Polyiso Insulation, EnergyGuard TM Polyiso Insulation	sulation, EnergyGuard™ RA	Polyiso
Insulation Minimum 1.3" thick	N/A	N/A
EnergyGuard TM Polyiso Insulation Min. 1.4" thick	N/A	N/A
EnergyGuard TM RA Composite Polyiso Insulation Minimum 1.5" thick	N/A	N/A
EnergyGuard TM Perlite Recover Board Minimum ³ / ₄ " thick	N/A	N/A
Structodek [®] High Density Fiber Board Minimum 1" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment. GAF requires either a ply of GAFGLAS[®] Stratavent[®] Eliminator[™] Perforated Venting Base Sheet laid dry or a layer of EnergyGuard[™] Perlite Roof Insulation or wood fiber overlay board on all isocyanurate applications.

Insulation for Top Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard TM Polyiso Insulation, EnergyGuard TM RA Polyiso Insula Minimum 1.3" thick	1, 2, 3 or 4	1:3 ft²
EnergyGuard TM RN Polyiso Insulation Minimum 1.4" thick	1, 2 or 3	1:3 ft²
EnergyGuard™ RA Composite Polyiso Insulation Minimum 1.5 thick	3	1:3 ft²
EnergyGuard TM Perlite Roof Insulation Minimum ³ / ₄ " thick	1, 2, 7 or 8	1:2 ft²
Structodek® High Density Fiber Board Minimum 1" thick	1, 2, 7 or 8	1:4 ft²



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13

Page 11 of 17

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment. GAF requires either a ply of GAFGLAS® Stratavent® Eliminator™ Perforated laid dry or a layer of EnergyGuard™ Perlite Roof Insulation or wood fiber overlay board on all isocyanurate applications.

Fire Barrier: FireOutTM Fire Barrier Coating, VersaShield[®] Fire Resistant Roof Deck Protection or

(optional) Securock™ Gypsum Fiber Roof Board.

Base Sheet: (Optional) Install one ply of GAFGLAS[®] #75 Base Sheet, GAFGLAS[®] #80 UltimaTM Base

Sheet, GAFGLAS® Ply 4, GAFGLAS FlexPlyTM 6, GAFGLAS® Stratavent® EliminatorTM Perforated Venting Base Sheet laid dry, Ruberoid® Mop Smooth or Ruberoid® 20 directly over the top layer of insulation. Adhere with any approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval the use of an

overlay board is approved; see General Limitation #4.

Ply Sheet: Two or more plies of GAFGLAS[®] Ply 4, GAFGLAS[®] FlexPlyTM 6 ply sheet or GAFGLAS[®]

#80 UltimaTM Base Sheet adhered in a full mopping of approved asphalt applied within the

EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GAFGLAS[®] Mineral Surfaced Cap Sheet or GAFGLAS[®] EnergyCap[™]

BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: Optional on granular surfaced membranes; required for smooth membranes. Chosen

components must be applied according to manufacturer's application instructions.

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat

of approved asphalt at 60 lbs./sq.

2. Topcoat[®] Surface Seal SB applied at 1to 1.5 gal./sq.

Maximum Design

Pressure: -45 psf; (See General Limitation #7)



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 12 of 17 **Deck Type 1I:** Wood, Insulated

Deck Description: ¹⁹/₂₂" or greater plywood or wood plank

System Type D: Insulation and Base sheet simultaneously

All General and System Limitations shall apply.

One or more layers of any of the following insulations.

Insulation Layer loosely laid with firmly butted joints.	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard TM Polyiso Insulation, EnergyGuard TM RA Polyis Minimum 1.3" thick	so Insulation N/A	N/A
Structodek® High Density Fiber Board Minimum 1" thick	N/A	N/A

Fire Barrier: FireOut™ Fire Barrier Coating, VersaShield® Fire Resistant Roof Deck Protection or

(optional) SecurockTM Gypsum Fiber Roof Board.

Base Sheet: Install one ply of GAFGLAS[®] #75 Base Sheet, GAFGLAS[®] #80 Ultima[™] Base Sheet,

GAFGLAS® Stratavent® Eliminator™ Nailable Venting Base Sheet or Ruberoid® 20 base sheet applied over the loose laid insulation with 2" side laps mechanically fastened as

described below:

Fastening Options: Drill-Tec[™] #12 Fastener or Drill-Tec[™] #14 Fastener and Drill-Tec[™] 3" Steel Plate, Drill-

TecTM AccuTrac[®] Flat Plate or Drill-TecTM AccuTrac[®] Recessed Plate is installed through the base sheet and insulation in 3 rows 12" o.c. One row is in the 2" side lap. The other

rows are equally spaced approximately 12" o.c. in the field of the sheet.

(Maximum Design Pressure -45 psf, See General Limitation #7)

Drill-TecTM #12 Fastener or Drill-TecTM #14 Fastener and Drill-TecTM 3" Steel Plate, Drill-TecTM AccuTrac[®] Flat Plate or Drill-TecTM AccuTrac[®] Recessed Plate is installed through the base sheet and insulation in 4 rows 8" o.c. One row is in the 2" side lap. The other 3 rows are equally spaced approximately 9" o.c. in the field of the sheet.

(Maximum Design Pressure –75 psf, See General Limitation #7)

GAFGLAS® #80 Ultima™ Base Sheet, Ruberoid® 20, Ruberoid® Mop Smooth, base sheet attached to deck with approved annular ring shank nails with a minimum embedment of 1" into the wood substrate and inverted 3" steel plate at a fastener spacing of 9" o.c. at the 4" lap and in two rows staggered with a fastener spacing of 9" o.c. in the center of the membrane.

(Maximum Design Pressure -60 psf, See General Limitation #7)

Drill-Tec[™] #12 Fastener and Drill-Tec[™] #14 Fastener and Drill-Tec[™] 3" Steel Plate, Drill-Tec[™] AccuTrac[®] Flat Plate or Drill-Tec[™] AccuTrac[®] Recessed Plate in 4 rows 12" o.c. One row is in the 2" side lap. The other rows are equally spaced approximately 9" o.c. in the field of the sheet.

(Maximum Design Pressure -60 psf, See General Limitation #7)

Ply Sheet: One or more plies GAFGLAS® Ply 4, GAFGLAS® FlexPlyTM 6 or GAFGLAS® #80 Ultima

Base Sheet adhered in a full mopping of approved asphalt applied within the EVT range and

at a rate of 20-40 lbs./sq.

MIAMI-DADE COUNTY
APPROVED

NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 13 of 17

(Optional) One ply of GAFGLAS® Mineral Surfaced Cap Sheet or GAFGLAS® **Cap Sheet:**

EnergyCap™ BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved

asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: Optional on granular surfaced membranes; required for smooth membranes. Chosen

components must be applied according to manufacturer's application instructions

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat

of approved asphalt at 60 lbs./sq.

2. Topcoat[®] Surface Seal SB applied at 1to 1.5 gal./sq.

Maximum Design

Pressure: See Fastening Above



NOA No.: 13-0424.09 **Expiration Date: 11/04/14** Approval Date: 10/31/13

Page 14 of 17

Deck Type 1: Wood, Non-insulated

Deck Description: $\frac{19}{3}$ or greater plywood or wood plank decks

System Type E: Base sheet mechanically fastened.

All General and System Limitations shall apply.

Fire Barrier: FireOutTM Fire Barrier Coating, VersaShield[®] Fire Resistant Roof Deck Protection or

(optional) Securock™ Gypsum Fiber Roof Board.

Base sheet: GAFGLAS® #80 UltimaTM Base Sheet, Stratavent® EliminatorTM Nailable Venting Base

Sheet, Ruberoid[®] 20, Ruberoid[®] SBS Heat-Weld[™] Smooth or Ruberoid[®] SBS Heat-

WeldTM 25 base sheet mechanically fastened to deck as described below;

Fastening Options: GAFGLAS[®] Ply 4, GAFGLAS[®] FlexPlyTM 6, GAFGLAS[®] #75 Base Sheet or any of above

base sheets attached to deck with approved annular ring shank nails and tin caps at a fastener spacing of 9" o.c. at the lap staggered and in two rows 12" o.c. in the field.

(Maximum Design Pressure -45 psf, See General Limitation #7)

GAFGLAS® Ply 4, GAFGLAS® FlexPlyTM 6, GAFGLAS® #75 Base Sheet or any of above base sheets attached to deck with Drill-TecTM #12 Fastener or Drill-TecTM #14 and Drill-

Tec[™] 3" Steel Plate, Drill-Tec[™] AccuTrac[®] Flat Plate or Drill-Tec[™] AccuTrac[®] Recessed Plate 12" o.c. in 3 rows. One row is in the 2" side lap. The other rows are

equally spaced approximately 12" o.c. in the field of the sheet. (Maximum Design Pressure -45 psf, See General Limitation #7)

GAFGLAS® Flex PlyTM 6, GAFGLAS® #75 Base Sheet or any of above base sheets attached to deck with approved annular ring shank nails and tin caps at a fastener spacing of 9" o.c. at the 4" lap staggered and in two rows 9" o.c. in the field.

(Maximum Design Pressure -52.5 psf, See General Limitation #7)

GAFGLAS[®] #80 Ultima[™] Base Sheet, Ruberoid[®] 20, Ruberoid[®] Mop Smooth, base sheet attached to deck with approved 1½" annular ring shank nails and inverted 3" steel plate at a fastener spacing of 9" o.c. at the 4" lap and in two rows staggered with a fastener spacing of 9" o.c. in the center of the membrane.

(Maximum Design Pressure –60 psf, See General Limitation #7)

GAFGLAS® #75 Base Sheet or any of above base sheets attached to deck with Drill-TecTM #12 Fastener or Drill-TecTM #14 Fastener and Drill-TecTM 3" Steel Plate, Drill-TecTM AccuTrac® Flat Plate or Drill-TecTM AccuTrac® Recessed Plate 12" o.c. in 4 rows. One row is in the 2" side lap. The other rows are equally spaced approximately 9" o.c. in the field of the sheet.

(Maximum Design Pressure -60 psf, See General Limitation #7)

Any of above Base sheets attached to deck approved annular ring shank nails and 3" inverted Drill-Tec™ insulation plates at a fastener spacing of 9" o.c. at the 4" lap staggered in two rows 9" in the field.

(Maximum Design Pressure –60 psf, See General Limitation #7)



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 15 of 17 GAFGLAS® #75 Base Sheet or any of above base sheets attached to deck with Drill-TecTM #12 Fastener or Drill-TecTM #14 Fastener and Drill-TecTM 3" Steel Plate, Drill-TecTM AccuTrac® Flat Plate or Drill-TecTM AccuTrac® Recessed Plate 8" o.c. in 4 rows. One row is in the 2" side lap. The other rows are equally spaced approximately 9" o.c. in the field of the sheet.

(Maximum Design Pressure -75 psf, See General Limitation #7)

Ply Sheet: One or more plies of GAFGLAS® Ply 4 or GAFGLAS® #80 Ultima Base Sheet adhered in a

full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Cap Sheet: (Optional) One ply of GAFGLAS® Mineral Surfaced Cap Sheet or GAFGLAS®

EnergyCapTM BUR Mineral Surfaced Cap Sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

approved asphalt applied within the E v 1 range and at a rate of 20-40 ios./sq.

components must be applied according to manufacturer's application instructions

Optional on granular surfaced membranes; required for smooth membranes. Chosen

1. Gravel or slag applied at 400 lbs./sq. and 300 lbs./sq. respectively in a flood coat of approved asphalt at 60 lbs./sq.

2. Topcoat® Surface Seal SB applied at 1to 1.5 gal./sq.

Maximum Design

Surfacing:

Pressure: See Fastening Above



NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 16 of 17

WOOD DECK SYSTEM LIMITATIONS:

- 1 A slip sheet is required with GAFGLAS® Ply 4 and GAFGLAS® Flex PlyTM 6 when used as a mechanically fastened base or anchor sheet.
- 2. Minimum ¼" Dens DeckTM Roof Board or ½" Type X gypsum board is acceptable to be installed directly over the wood deck.

GENERAL LIMITATIONS:

- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
- 3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
- 4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
- 5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
- 6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
- 7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant (When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
- 8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
- 9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). (When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
- 10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY
APPROVED

NOA No.: 13-0424.09 Expiration Date: 11/04/14 Approval Date: 10/31/13 Page 17 of 17